



TO BE FURNISHED AND INSTALLED BY CUSTOMER

1. Weatherproof enclosure for circuit breaker and appropriate size meter base (minimum of 60 AMP).
2. 5/8" x 8' galvanized or copper coated ground rod with U.L. approved ground clamp.
3. Pipe straps to be attached with wood screws only.
4. Number 6 copper ground wire attached to meter base
5. Minimum 4" x 6" x 8' treated pole or class 7 post.
6. Weatherproof duplex GFI receptacles.

NOTES:

1. Pole location must be spotted by LEC personnel prior to installation.
2. Temp underground service pole to be installed no more than 5' from padmount transformer or secondary pedestal.
3. Temp pole MAY need to be inspected by local authorities.
4. Pole must be properly tamped and secure.
DO NOT USE CONCRETE.
5. Check local codes for all other applicable requirements.